



**CITY OF EAST PALO ALTO, CALIFORNIA
DEPARTMENT OF PUBLIC WORKS – ENGINEERING DIVISION**

ADDENDUM 1

TRASH CAPTURE DEVICES INSTALLATION PUBLIC WORKS PROJECT NO. SD-08

To all prospective bidders, you are advised that the bid Documents for the above referenced Project are amended and clarified, as follows:

General Information and Questions

Question 1: Please confirm if the City is specifically seeking a crescent shaped CPS device for this project, or if any Water Board certified CPS device will be acceptable regardless of its shape? United Storm Water's CPS device is rectangular shaped and specifications are attached.

Answer 1: Contractor will need to provide cut sheet or detail for City review and approval if the contractor to install different type of CPS Device as shown on the proposal. After review, the United Storm Water's CPS device is acceptable to be used as item #4 Connector Pipe Screen as shown on the bid schedule. The United Storm Water's CPS device fact sheet has been posted online with this addendum #1. If contractors choose to use United Storm Water's CPS device for bidding, please specify and indicate it below or adjacent to the bid item #4 Connector Pipe Screen.

Question 2: What is the estimated cost for this project?

Answer 2: The Engineering Estimate for this project is \$130,000

Question 3: Can I get a copy of any addendum that have been released to date?

Answer 3: All the addendum(s) has been/will be posted online at the City Bids and RFPs website link below, please check and get a copy there.

<https://www.cityofepa.org/rfps>

Ambrose Wong

Chin Hang (Ambrose) Wong
Special Projects Manager
City of East Palo Alto

ADDENDUM No.1, ACKNOWLEDGMENT

(To be submitted with the General Construction Contract as an attachment)

REQUEST FOR BID – TRASH CAPTURE DEVICES INSTALLATION

City Project: **SD-08**

Bidder acknowledges receipt of this addendum, which shall be attached to the bid. Acknowledgement of receipt of this addendum is required in the space provided below. Failure to acknowledge the addendum may subject the bidder to disqualification.

I, _____, representing _____ have carefully read this addendum, understand it, acknowledge receipt of it and will comply with its terms.

CONTRACTOR SIGNATURE

DATE