



CITY OF EAST PALO ALTO, CALIFORNIA  
DEPARTMENT OF PUBLIC WORKS – ENVIRONMENTAL DIVISION

---

## ADDENDUM 4

---

**1960 Tate St. Electric Vehicle Charging Stations Project**  
**CIP-FA-10**

General Information

1. **Pollution and Builder's Risk Insurances Waived:** These insurance requirements have been pre-emptively waived.

Questions

**Question 1:** For the Make Readies, will they need a junction box or a handhole since the plans only call for 2 concrete pads for EV?

**Answer 1:** Yes, a junction box for the "Make Readies" should be installed. Please account for the cost of this in the "Make Ready" line item in the bid schedule that you will be submitting.

*Fatima Khan*

---

Fatima Khan  
Environmental Services Aide  
City of East Palo Alto

**ADDENDUM No.4, ACKNOWLEDGMENT**

(To be submitted with the General Construction Contract, Attachment A of RFB)

REQUEST FOR BID – **1960 Tate St. Electric Vehicle Charging Stations Project**

City Project: **CIP-FA-10**

Bidder acknowledges receipt of this addendum, which shall be attached to the bid. Acknowledgement of receipt of this addendum is required in the space provided below. Failure to acknowledge the addendum may subject the bidder to disqualification.

I, \_\_\_\_\_, representing \_\_\_\_\_ have  
carefully read this addendum, understand it, acknowledge receipt of it and will comply with  
its terms.

\_\_\_\_\_  
CONTRACTOR SIGNATURE

\_\_\_\_\_  
DATE